



Fire Marshal's Office

1500 Highway 66
Garland, TX 75040
(972) 781-7148
(972) 781-7142 – fax

Food Truck Inspection Checklist

Revised 11/10/2023

\$50 Inspection fee required

Driver's License # _____

License plate # _____

Proof of Insurance _____

Fire Protection

Is exhaust hood provided over cooking equipment that produces grease-laden vapors?

Is automatic fire extinguishing system provided?

Does automatic fire extinguishing system have current inspection tag?

Is food truck provided with a Class K portable fire extinguisher?

Does fire extinguisher have a current inspection tag?

Is the exhaust system inspected and cleaned?

Cooking Oil

Aggregate volume of cooking oil does not exceed 120 gallons

Metallic storage tanks listed in accordance with UL 80 or UL 142?

Nonmetallic storage tank listed for use with cooking oil?

Nonmetallic storage tank capacity does not exceed 200 gallons.

Are normal vents provided for cooking storage tanks, above the normal liquid line and having a minimum effective area not smaller than the largest filling or withdrawal connection?

Are emergency vents provided for cooking oil storage tanks?



Fire Marshal's Office

1500 Highway 66
Garland, TX 75040
(972) 781-7148
(972) 781-7142 – fax

LP-gas Systems

Maximum aggregate capacity of LP-gas containers does NOT exceed 200 lbs.

LP-gas containers are securely mounted and restrained to prevent movement?

LP-gas system has been inspected by licensed plumber within last 12 months.

LP-gas alarm installed within the vehicle in the vicinity of LP-gas components.

CNG Systems

Maximum aggregate capacity of CNG containers does NOT exceed 1300 lbs. water capacity?

CNG containers are securely mounted and restrained to prevent movement?

CNG containers are NOT installed in locations subject to direct vehicle impact?

CNG container is NGV-2 cylinder?

CNG system has been inspected by licensed plumber within the last 12 months?

Is a methane gas alarm installed within the vehicle?

For items not listed refer to 2021 IFC, local amendments, and any material deemed applicable by the Fire Marshal.

<http://www.garlandtx.gov/312/Fire-Prevention>

This list is provided as an aid for submittals only and is not intended to cover every code requirement.