



## Fire Marshal's Office

1500 Highway 66  
Garland, TX 75040  
(972) 781-7148  
(972) 781-7142 – fax

# Private Hydrants

Revised 09/15/2020

The Garland Fire Department must be provided documentation on all private fire hydrants showing they have been inspected, tested and maintained in accordance with the following guidelines from the National Fire Protection Association (NFPA):

**507.5.3 Private fire service mains and water tanks.** Private fire service mains and water tanks shall be periodically inspected, tested and maintained in accordance with NFPA 25 at the following intervals:

1. Private fire hydrants of all types: Inspection annually and after each operation; flow test and maintenance annually.
2. Fire service main piping: Inspection of exposed, annually; flow test every 5 years.
3. Fire service main piping strainers: Inspection and maintenance after each use.

Documentation may be sent via [email GFDPLANSREVIEW@GARLANDTX.GOV](mailto:GFDPLANSREVIEW@GARLANDTX.GOV) or may be faxed to the Fire Marshal's Office (972) 781-7142. If you have any questions regarding this policy, please contact us at (972) 781-7148.

**For items not listed refer to 2015 IFC, NFPA 25, local amendments, and any material deemed applicable by the Fire Marshal.**

<http://www.garlandtx.gov/312/Fire-Prevention>

**This list is provided as an aid for submittals only, and is not intended to cover every code requirement.**